

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN45564

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC contactor

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing City,
Zhejiang Province

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGC1-2511,TGC1-2511N,TGC1-3211,TGC1-3211N,TGC1-3811,TG
C1-3811N,TGCG-2511,TGCG-2511N,TGCG-3211,TGCG-3211N,TG
CG-3811,TGCG-3811N , TGCJH-2511, TGCJH-2511N, TGCJH
-3211, TGCJH-3211N, TGCJH -3811, TGCJH-3811NAdditional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2009(3rd Edition) + AMD 1:2012

As shown in the Test Report Ref. No. which
forms part of this Certificate

03601-A-18CB0053-S-A;03601-A-18CB0053-S-B

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.26,2018

Signature:

陆梅

Lu Mei



CB 0049708

TGC1-2511,TGC1-2511N,TGC1-3211,TGC1-3211N,TGC1-3811,TGC1-3811N,TGCG-2511,TGCG-2511N,TGCG-3211,TGCG-3211N,TGCG-3811,TGCG-3811N, TGCJH-2511, TGCJH-2511N, TGCJH-3211, TGCJH-3211N, TGCJH-3811, TGCJH-3811N;

Ui:690V;

Uimp:6kV;

Ith:32A(TGC1-2511,TGC1-2511N, TGCG-2511,TGCG-2511N, TGCJH-2511, TGCJH-2511N),

40A(TGC1-3211,TGC1-3211N, TGCG-3211,TGCG-3211N, TGCJH-3211, TGCJH-3211N),

50A(TGC1-3811,TGC1-3811N, TGCG-3811,TGCG-3811N, TGCJH-3811, TGCJH-3811N);

TGC1-2511, TGCG-2511, TGCJH-2511:

AC-1:Ue:AC220V/230V,380V/400V,Ie:32A

AC-3:Ue:AC220V/230V,380V/400V,Ie:25A

Ue:AC660V/690V,Ie:18A

AC-4:Ue:AC220V/230V,380V/400V,Ie:8.5A

Ue:AC660V/690V,Ie:4.4A

TGC1-2511N, TGCG-2511N, TGCJH-2511N:

AC-1:Ue:AC220V/230V,380V/400V,Ie:32A

AC-4:Ue:AC220V/230V,380V/400V,Ie:8.5A

Ue:AC660V/690V,Ie:4.4A

TGC1-3211, TGCG-3211, TGCJH-3211:

AC-1:Ue:AC220V/230V,380V/400V,Ie:40A

AC-3:Ue:AC220V/230V,380V/400V,Ie:32A

Ue:AC660V/690V,Ie:22A

AC-4:Ue:AC220V/230V,380V/400V,Ie:12A

Ue:AC660V/690V,Ie:7.5A

TGC1-3211N, TGCG-3211N, TGCJH-3211N:

AC-1:Ue:AC220V/230V,380V/400V,Ie:40A

AC-4:Ue:AC220V/230V,380V/400V,Ie:12A

Ue:AC660V/690V,Ie:7.5A

TGC1-3811, TGCG-3811, TGCJH-3811:

AC-1:Ue:AC220V/230V,380V/400V,Ie:50A

AC-3:Ue:AC220V/230V,380V/400V,Ie:38A

Ue:AC660V/690V,Ie:22A

AC-4:Ue:AC220V/230V,380V/400V,Ie:14A

Ue:AC660V/690V,Ie:8.9A

TGC1-3811N, TGCG-3811N, TGCJH-3811N:

AC-1:Ue:AC220V/230V,380V/400V,Ie:50A

AC-4:Ue:AC220V/230V,380V/400V,Ie:14A

Ue:AC660V/690V,Ie:8.9A

Us: AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50Hz;

AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;

3P;


IP20;

Page 1 of 2

Additional information (if necessary)

Date: Dec.26,2018

Signature:



Lu Mei

Attached auxiliary contacts: (1NO1NC,2 pairs):
Ith:10A;Ui:690V;Uimp:6kV;
AC-15:Ue/Ie:AC380V/0.95A, AC220V/1.6A
DC-13:Ue/Ie:DC220V/0.15A.

Page 2 of 2

Additional information (if necessary)

Date: Dec.26,2018

Signature:



Lu Mei