

Test Report issued under the responsibility of:



TEST REPORT EN 60947-6-1 Low-voltage switchgear and controlgear Part 6-1: Multiple function equipment – Transfer switching equipment	
Report Number.....	: 03601-A-23D0064 S-A1
Date of issue	: 2023-06-29
Total number of pages	: 11 pages
Name of Testing Laboratory preparing the Report.....	: Suzhou Electrical Apparatus Science Research Institute Co., Ltd (EET)
Applicant's name	: Zhejiang Tengen Electric Co.,Ltd.
Address.....	: Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Test specification:	
Standard	: EN 60947-6-1:2005 / A1:2014
Test procedure	: CCA Scheme
Non-standard test method.....	: N/A
Test Report Form No.	: EN60947_6_1C
Test Report Form(s) Originator....	: SGS Fimko Ltd
Master TRF	: Dated 2019-07-02
Copyright © 2019 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer:	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

Test item description	Automatic Transfer Switching Equipment	
Trade Mark	TENGEN	
Manufacturer	Zhejiang Tengen Electric Co.,Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China	
Model/Type reference	TGQ1NPL-63, TGQKPL-63	
Ratings	See page 7	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	Testing Laboratory:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)
	Testing location/ address	No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
	Tested by (name, function, signature)	Fang Gang (Team leader)
	Approved by (name, function, signature) ..	Xu Jianlin (Supervisor)
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
	Testing location/ address	
	Tested by (name, function, signature)	
	Approved by (name, function, signature) ..	
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
	Testing location/ address	
	Tested by (name, function, signature)	
	Witnessed by (name, function, signature) .	
	Approved by (name, function, signature) ..	
<input type="checkbox"/>	Testing procedure: CTF Stage 3 or 4:	
	Testing location/ address	
	Tested by (name, function, signature)	
	Witnessed by (name, function, signature) .	
	Approved by (name, function, signature) ..	
	Supervised by (name, function, signature) :	

